TEST CERTIFICATE

Issued to:	EAE Elektroteknik San. Ve Tic. A.S. İkitelli O.S.B. Ziya Gokalp Mah Eski Turgut Özal Cad No: 20 34306 Başakşehir / İstanbul Türkiye
For the product:	Empty enclosure for low-voltage switchgear and controlgear assemblies
Trade name:	EAE
Type/Model:	E-Kabin L Series
Ratings:	IP55 (single door), IP54 (double door), IK08, indoor For more details see annex
Manufactured by:	EAE Elektroteknik San. Ve Tic. A.S. İkitelli O.S.B. Ziya Gokalp Mah Eski Turgut Özal Cad No: 20 34306 Başakşehir / İstanbul Türkiye
Subject:	Type tests
Requirements:	IEC 62208:2023 Clauses 9.3, 9.4, 9.5, 9.6, 9.7, 9.8, 9.9, 9.10, 9.12, 9.14, 9.15
Remarks:	Date of performance of tests: 2009-2014 and 2022-2025 (see general notes on tests in the report)

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2299581.02-INC, dated 21 August 2025.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 26 August 2025

Number: 2299581.101

DEKRA Certification B.V.

S. Vasylyeva
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396